



- NOTES:
1. REFLECTS .75" FELT ALLOWANCE
 2. SPACING VARIES FOR EACH TANK SIZE. SEE PIER INSTALLATION DRAWING
 3. MATERIAL IS 5000PSI CONCRETE
 4. 3" I.D. SCH. 40 THRU FOR LIFTING
 5. GRADE MAY VARY
 6. ENGINEERING DATA AND/OR ADDITIONAL INFORMATION AVAILABLE UPON REQUEST

TOLERANCES: INCHES
 FRACTIONAL $\pm 1/8$
 ANGULAR $\pm 1^\circ$

PROPRIETARY AND CONFIDENTIAL
 THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF LPG VENTURES. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF LPG VENTURES IS PROHIBITED.

REVISIONS			
NO.	DESCRIPTION	DRW/CCL	DATE
0	APPROVED FOR FAB.	C.H./C.H.	04/20/15



LPG VENTURES
 971 North Jefferson Street
 Kearney, MO 64060
 (816) 903-1806
 Fax: (816) 903-1810
 Toll Free: (888) 739 8764

CUSTOMER:	LPG VENTURES
DESCRIPTION:	PIER FOR 60" OD TANK
DWG NO:	PIER 60
SCALE:	SHEET 1 OF 1
REV:	0